

## Neil Jamieson

**From:** Karly Bussemakers <KBussemakers@acrwc.ab.ca>  
**Sent:** Thursday, May 4, 2023 7:40 AM  
**To:** Jaitik Berawala  
**Cc:** Neil Jamieson; Brianne O'Halloran; Wade Teveniuk; Dwayne Cikaluk; Source Control Grp  
**Subject:** Parkland Septage Receiving Station Violations ( April 18 & April 19)  
**Attachments:** EO2303080\_0\_COA - PK1.pdf; EO2303082\_0\_COA PK2.pdf

Some people who received this message don't often get email from kbussemakers@acrwc.ab.ca. [Learn why this is important](#)

Good morning,

Samples that were collected on April 18 and April 19 resulted in the following violations:

**Facility: Parkland Transfer Station, Golf Course Road**

**Date:** April 18<sup>th</sup> & April 19<sup>th</sup>

*Sample Type: 24 hour composite*

Suspended Solids, Total (TSS)	= 11,800 mg/L (Limit = 5,000 mg/L)
Oil & Grease, Total	= 1,080 mg/L (Limit = 500 mg/L)
Kjeldahl Nitrogen, Total (TKN)	= 540 mg/L (Limit = 500 mg/L)

**Facility: Parkland Transfer Station Villeneuve**

*Date: April 18<sup>th</sup> & April 19<sup>th</sup>*

*Sample Type: 24 hour composite*

Suspended Solids, Total (TSS)	= 9,690 mg/L (Limit = 5,000 mg/L)
Oil & Grease, Total	= 1,570 mg/L (Limit = 500 mg/L)
Kjeldahl Nitrogen, Total (TKN)	= 694 mg/L (Limit = 500 mg/L)

The April manifests will be reviewed to determine if there is a potential source for any of these violations that requires further action. Please do not hesitate to contact me if you have any questions or concerns.

Regards,

**Karly Bussemakers** (*she/her*) | Source Control, Regulatory Services



**Alberta Capital Region  
Wastewater Commission**

23262 Township Road 540  
Fort Saskatchewan, AB T8L 4A2  
Located on ᐃᓂᑦᐱᑦᐱᑦᐱᑦᐱᑦᐱᑦ (Amiskwacîwâskahikan), Treaty 6 / Métis Territory  
p : 780.416.9968 m: 780.918.4274  
e : kbussemakers@acrwc.ab.ca | w : www.acrwc.ab.ca